15A NCAC 02D .0519 CONTROL OF NITROGEN DIOXIDE AND NITROGEN OXIDES EMISSIONS

- (a) The emissions of nitrogen dioxide shall not exceed 5.8 pounds per ton of acid produced from any sulfuric acid manufacturing plant.
- (b) The emissions of nitrogen oxides shall not exceed:
 - (1) 0.8 pounds per million BTU of heat input from any oil or gas-fired boiler with a capacity of 250 million BTU per hour or more;
 - (2) 1.8 pounds per million BTU of heat input from any coal-fired boiler with a capacity of 250 million BTU per hour or more.
- (c) The emission limit for a boiler that burns both coal and oil or gas in combination shall be calculated by the equation E = [(Ec) (Qc) + (Eo) (Qo)] / Qt.
 - (1) E =the emission limit for combination in pounds per million BTU.
 - (2) Ec = emission limit for coal only as determined by Paragraph (b) of this Rule in pounds per million BTU.
 - (3) Eo = emission limit for oil or gas as determined by Paragraph (b) of this Rule in pounds per million BTU.
 - (4) Qc = the actual coal heat input to the combination in BTU per hour.
 - (5) Qo = the actual oil and gas heat input to the combination in BTU per hour.
 - (6) Qt = Qc + Qo and is the actual total heat input to the combination in BTU per hour.
- (d) A boiler subject to an emission standard for nitrogen oxides under Rule .0524 (New Source Performance Standards) or .1418 (New Generating Units, Large Boilers, and Large I/C Engines) of this Subchapter shall meet the standard in that particular rule instead of the standard in Paragraph (a) of this Rule.

History Note: Authority G.S. 143-215.3(a)(1); 143-215.107(a)(5);

Eff. February 1, 1976;

Amended Eff. July 1, 2007; January 1, 2005; July 1, 1996; October 1, 1989; January 1, 1985.