

Coal Ash Facility	Property Address	Public or Private	Well Owner ID	No. of Wells on Property	Notes	15A NCAC 02L .0202 Groundwater Standard:																																										
						NS	1 ug/L	10 ug/L	700 ug/L	NS (interim state standard) 4 ug/L	700 ug/L	2 ug/L	NS	10 ug/L	NS (interim state standard) 1 ug/L	1 mg/L	300 ug/L	NS	15 ug/L	NS	50 ug/L	1 ug/L	NS	100 ug/L	NS	20 ug/L	NS	0.2 ug/L	NS (interim state standard) 0.3 ug/L	1 mg/L	250 mg/L	250 mg/L	NS	NS	NS	500 mg/L	NS	NS	6.5-8.5 su	NS	NS	NS	NS					
						Federal MCL (* denotes secondary standard)	*50 to 200 ug/L	6 ug/L	10 ug/L	2000 ug/L	4 ug/L	NS	5 ug/L	NS	100 ug/L	NS	1.3 mg/L	*300 ug/L	NS	15 ug/L	NS	*50 ug/L	2 ug/L	NS	NS	NS	50 ug/L	NS	NS	2 ug/L	NS	*5 mg/L	*250 mg/L	*250 mg/L	NS	NS	NS	*500 mg/L	NS	NS	NS	NS	NS	6.5 - 8.5 su	NS	NS	NS	NS
						DHHS Screening Level	3500 ug/L	1 ug/L	10 ug/L	700 ug/L	4 ug/L	700 ug/L	2 ug/L	NS	10 ug/L	1 ug/L	1 mg/L	2500 ug/L	.07 ug/L	15 ug/L	NS	200 ug/L	1 ug/L	18 ug/L	100 ug/L	NS	20 ug/L	20000 ug/L	2100 ug/L	.2 ug/L	.3 ug/L	1 mg/L	250 mg/L	250 mg/L	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
Aluminum (ug/L)	Antimony (ug/L)	Arsenic (ug/L)	Barium (ug/L)	Beryllium (ug/L)	Boron (ug/L)	Cadmium (ug/L)	Calcium (ug/L)	Chromium (ug/L)	Cobalt (ug/L)	Copper (mg/L)	Iron (ug/L)	Hexavalent Chromium (ug/L)	Lead (ug/L)	Magnesium (ug/L)	Manganese (ug/L)	Mercury (ug/L)	Molybdenum (ug/L)	Nickel (ug/L)	Potassium (ug/L)	Selenium (ug/L)	Sodium (ug/L)	Strontium (ug/L)	Thallium (ug/L)	Vanadium (ug/L)	Zinc (mg/L)	Chloride (mg/L)	Sulfate (mg/L)	Alkalinity (mg/L)	Bicarbonate (mg/L)	Carbonate (mg/L)	Total Dissolved Solids (mg/L)	Total Suspended Solids (mg/L)	Turbidity (NTU)	pH (su)	Temperature (°C)	Specific Conductance (umhos/cm)	Dissolved Oxygen (mg/L)	Oxidation-Reduction Potential (mv)										
Allen Steam Station	2072 South Point Road Belmont, NC 28012	Private	AL1	1	Filter prior to sample port.	<50	<1	<5	26	<1	<100	<0.1	15000	<1	<1	0.01	65	<10	<2	2800	<5	<0.2	<5	<5	2100	<5	6700	130	<0.1	5	0.155	4.63	<1	47	47	<0	98	<1	<1	6.6	18.1	128	6.9	207				
Allen Steam Station	91 Mitchell Street Belmont, NC 28012	Private	AL100	1		12.1	<3	<10	14.5	<1	<100	<0.1	15200	<10	<5	<0.01	19.7.1	<20	3.11.1	5120	1400	<0.2	<10	<10	1680	<10	8610	162	<1	10	0.0479	5.22	<1	10	66.5	66.5	<1	134	<1	<1	6.89	17.1	215	5.42	NA			
Allen Steam Station	1002 Nutall Oak Lane Belmont, NC 28012	Private	AL103	1	high turbidity	870	.078.1	<1	29	<1	<500	0.22.1	11000	7.2	0.74.1	0.0037.1	2700	<10	<0.7	3.6	2500	<1	7200	110	<1	9.1	0.48.8H.8	1.4	<1	57	57	<5	120	34	18	6.2	17	101	7.5	170								
Allen Steam Station	2369 South Point Road Belmont, NC 28012	Private	AL11	1		<50	<3	<10	33.4	<1	<100	<0.1	10500	2.28.1	<5	0.00416.1	<50	<20	2.98.1	2910	3.6	<0.2	<10	<10	1550	<10	8360	135	<1	4.35.1	0.00499.1	4.28	<1	104	<5	<1	6.88	19.3	157	6.52	NA							
Allen Steam Station	1024 Nutall Oak Lane Belmont, NC 28012	Private	AL113	1		15.1	0.1.1	<1	26	<1	49.1	0.067.1	11000	0.8.1	0.068.1	0.0016.1	<50	<10	0.11.1	3000	2.1	<0.2	<2	0.7.1	2100	<1	8600	110	0.063.1	9.5	0.026	2.5	0.60.1	58	58	<5	140	<1	<1	6.4	9.7	110	5.2	166				
Allen Steam Station	565 River Run, Belmont, NC	Private	AL117	1		77	0.089.1	<1	170	<1	120.1	<1	39000	1.4	0.11.1	0.023	200	<10	1.3	12000	3.5.1	<0.2	1.1.1	1.6.1	4100	<1	18000	440	<1	5.1	0.017	32	34	140	NA	<5	270	1.6.1	1.4	6.1	36.5	385	5.7	NA				
Allen Steam Station	2351 Southpoint Road Belmont, NC 28012	Private	AL118	1		<50	<1	<5	65	<1	<100	<0.1	13000	2	<1	0.056	<50	<10	5	4300	<5	<0.2	<5	<5	1600	<5	8100	230	<0.1	6	0.026	4.47	1.09	48	48	<0	106	<1	<1	5.7	19.3	135	4.9	241				
Allen Steam Station	2411 South Point Road Belmont, NC 28012	Private	AL14	1	Unable to collect samples from the well head due to pressure tank at well. Samples were collected from the spigot on the back of the house.	<50	<1	<5	96	<1	<100	<0.1	31000	4	<1	0.03	<50	5.1	<2	7900	<5	<0.2	<5	<5	1900	<5	10000	360	<0.1	2	0.021	22.3	6.92	61.7	61.7	<1	138	<5	<1	5.9	19.2	276	5.8	213				
Allen Steam Station	2417 South Point Road Belmont, NC 28012	Private	AL15	1	Per lab, no tap @ well head and no treatment devices.	<50	<3	<10	49.2	<1	<100	<0.1	19600	<10	<5	0.0276	14.5.1	<20	<5	6080	<10	<0.2	<10	<10	1570	<10	9300	222	<1	3.68.1	<0.01	7.6	<10	72.8	72.8	<1	138	<5	<1	6.69	15.7	252	5.82	NA				
Allen Steam Station	114 Warren Drive Belmont, NC 28012	Private	AL16	1	Unable to collect samples from the well head. Samples were collected from the spigot on front of house.	89	<1	<5	16	<1	<100	<0.1	11000	2	<1	0.006	510	<10	<2	2600	9	<0.2	<5	<5	1000	<5	8000	150	<0.1	3	0.784	3.86	<1	53.9	53.9	<1	138	<5	<1	6.69	15.7	252	5.82	NA				
Allen Steam Station	310 Mitchell Street Belmont, NC 28012	Private	AL17	1	Per lab, no well head tap. Sample taken from outside tap. No treatment.	<50	<3	<10	31.4	<1	<100	<0.1	13500	<10	<5	0.0162	57.7	<20	<5	3860	1.37.1	<0.2	<10	<10	1180	<10	9650	160	<1	5.58	0.0173	3.8	<10	56.9	56.9	<1	106	<5	<1	6.45	15.5	176	5.87	NA				
Allen Steam Station	318 Mitchell Street Belmont, NC 28012	Private	AL19	1	Per lab, no tap @ well head. Outside spigot closest to well. No treatment.	<50	<3	<10	51	<1	<100	<0.1	16600	<10	<5	0.033	19.4.1	<20	<5	5180	<10	<0.2	<10	<10	2000	<10	9830	228	<1	3.84.1	0.0112	8.08	<1	55.9	55.9	<1	106	<5	<1	6.45	15.5	176	5.87	NA				
Allen Steam Station	2360 South Point Road Belmont, NC 28012	Private	AL2	1		21.9	<0.5	0.64	22.2	<0.2	6.6	<0.08	16500	1.5	<0.5	<0.003	<50	1	0.12	4320	0.92	<0.2	1.2	<0.5	2170	0.66	8210	142	<0.1	9.9	0.0077	2.6	3	60.7	60.7	<5	114	<5	<1	7	17.2	158.6	5.3	168.8				
Allen Steam Station	131 South Point Drive Belmont, NC 28012	Private	AL20	1		<50	<3	<10	21.7	<1	<100	<0.1	13400	<10	<5	<0.01	<50	<20	<5	4390	<10	<0.2	<10	<10	1430	<10	65.7	165	<1	10.3	<0.01	4.28	<10	70.1	65.7	<1	84	<5	<1	7.11	13.8	174	6.12	NA				
Allen Steam Station	135 South Point Drive Belmont, NC 28012	Private	AL21	1		<50	<3	<10	23.2	<1	<100	<0.1	11800	<10	<5	<0.01	<50	<20	<5	5190	<10	<0.2	<10	<10	1740	<10	7910	152	<1	11.7	.00575.1	2.38	<10	70.1	70.1	<1	84	<5	<1	7.24	13.6	191	6.91	NA				
Allen Steam Station	122 South Point Drive Belmont, NC 28012	Private	AL23	1		19.1	<1	<1	15	<0.40	<25	<0.01	10000	<5.0	0.29.1	0.018	310	<10	0.13.1	3000	1.4.1	0.05.8.1	0.57.1	1.5.1	2000	<1.0	6400	100	<0.50.1	13	0.054.1	2.2	0.64.1	48	44	<10	57	<10	57	<10	6.99	14.1	79	5.52	94			
Allen Steam Station	116 South Point Drive Belmont, NC 28012	Private	AL24	1		<50	<1	<5	10	<1	<100	<0.1	11000	<1	<1	<0.005	<50	<10	<2	3200	<5	<0.2	2.1	<5	1800	<5	5700	82	<0.1	12	0.011	2.11	1.86	49	49	<0	99	<1	<1	7.3	20.1	116	4.9	197				
Allen Steam Station	110 South Point Drive Belmont, NC 28012	Private	AL25	1		<50	0.081.1	<1	73	<1	<100	<0.1	15000	1.4	<1	0.059	<50	<10	0.3.1	3900	0.63.1	<0.2	0.14.1	0.24.1	2400	<1	9830	280	<1	4.3.1	0.028	8	4.24	<1	60	60	<5	140	<3.3	0.15.1	6.2	15.7	162	8.6	215			
Allen Steam Station	305 Mitchell Street Belmont, NC 28012	Private	AL26	1	Per lab, outside spigot and no treatment devices.	<50	<3	<10	42	<1	<100	<0.1	16200	<10	<5	0.0078.1	15.6.1	<20	<5	4970	<10	<0.2	<10	<10	1930	<10	8670	178	<1	6.08	0.0117	7.6	<10	54.8	54.8	<1	102	<5	<1	7.05	14.7	217	6.74	NA				
Allen Steam Station	301 Mitchell Street Belmont, NC 28012	Private	AL27	1		<50	<1	<5	50	<1	<100	<0.1	17000	2	<1	0.006	<50	<10	<2	5300	<5	<0.2	<5	<5	1600	<5	9400	230	<0.1	4	0.083	8.29	<1	52.9	52.9	<0	144	<1	<1	6.5	21	180	5.8	207				
Allen Steam Station	109 Mitchell Street Belmont, NC 28012	Private	AL28	1		<50	0.04.1	<1	18.8	<0.11.1	14.8	<0.11.1	6500	2.05	<0.03.1	0.0219	<25	2.05.1	3.79	2660	0.84.1	<0.2	0.2.1	550	<0.016.1	5580	75	<0.06.1	13	0.0212.1	6.8	NA	NA	152	<2.5	<1	7.03	14.8	105	7.91	NA							
Allen Steam Station	103 Mitchell Street Belmont, NC 28012	Private	AL29	1		<50	0.072.1	<1	19	<1	<100	<0.1	4900	2.3	<1	0.0045.1	<50	<10	0.72.1	1800	0.64.1	<0.2	0.32.1	0.55.1	1800	<1	6300	72	<1	8.3	0.048	8H.8	2.5	<1	29	29	<5	92	<3	0.2.1	6.4	15	69	9.2	149			
Allen Steam Station	2320 South Point Road Belmont, NC 28012	Private	AL3	1		68	0.2.1	<1	17	<1	49.1	<1	4600	1.1	0.099.1	1.1.1	100	<10	0.46.1	1700	5.2	<0.2	0.36.1	0.33.1	1300	<1	5700	74	<1	6.8	0.033	2	0.15.1	26	26	<5	70	<3.1	0.9.1	6.3	16.2	55	10.3	221				
Allen Steam Station	111 South Point Drive Belmont, NC 28012	Private	AL30	1	Per lab, sample taken at kitchen sink tap. No well head access. No treatment before kitchen tap.	<50	<3	<10	55.5	<1	<100	<0.1	15200	2.41.1	<5	0.0703	<50	<20	<5	3720	<10	<0.2	<10	<10	1710	<10	8760	210	<1	5.07	0.018	9.02	<10	55.8	55.8	<1	113	<5	<1	6.48	14.7	191	7.28	NA				
Allen Steam Station	123 South Point Drive Belmont, NC 28012	Private	AL33	1	Per lab, no well head tap. Sample taken from outside tap. No treatment.	<50	<3	<10	15.4	<1	<100	<0.1	7430	<10	<5	0.00659.1	<50	<20	1.58.1	2030	<10	<0.2	<10	<10	901	<10	6540	119	<1	5.38	<0.01	3.32	<10	38.3	38.3	<1	52	<5	<1	6.4	13.7	108	6.83	NA				
Allen Steam Station	125 South Point Drive Belmont, NC 28012	Private	AL34	1	Per lab, no well head tap. Sample taken from outside tap. No treatment.	<50	<3	<10	29.9	<1	<100	<0.1	9950	<10	<5	0.00644.1	<50	<20	<5	2790	<10	<0.2	<10	<10	992	<10	7510	139	<1	8.43	0.0025.1	4.28	<10	49.3	49.3	<1	82	<5	<1	6.45	15.5	130	6.82	NA				
Allen Steam Station	2708 South Point Road Belmont, NC 28012	Private	AL39	2	Well A - unoperational well (per lab). Sample was taken with the bailer.	<10.1	<0.4.1																																									



Coal Ash Facility	Property Address	Public or Private	Well Owner ID	No. of Wells on Property	Notes	15A NCAC 02L .0202 Groundwater Standard:																																															
						NS	1 ug/L	10 ug/L	700 ug/L	NS (interim state standard) 4 ug/L	700 ug/L	2 ug/L	NS	10 ug/L	NS (interim state standard) 1 ug/L	1 mg/L	300 ug/L	NS	15 ug/L	NS	50 ug/L	1 ug/l	NS	100 ug/L	NS	20 ug/L	NS	NS	0.2 ug/L	NS (interim state standard) 0.3 ug/L	1 mg/L	250 mg/L	250 mg/L	NS	NS	NS	500 mg/L	NS	NS	NS	6.5-8.5 su	NS	NS	NS	NS								
						Federal MCL (* denotes secondary standard)	*50 to 200 ug/L	6 ug/L	10 ug/L	2000 ug/L	4 ug/L	NS	5 ug/L	NS	100 ug/L	NS	1.3 mg/L	*300 ug/L	NS	15 ug/L	NS	*50 ug/L	2 ug/L	NS	NS	NS	50 ug/L	NS	NS	NS	2 ug/L	NS	*5 mg/L	*250 mg/L	*250 mg/L	NS	NS	NS	*500 mg/L	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
						DHHS Screening Level	3500 ug/L	1 ug/L	10 ug/L	700 ug/L	4 ug/L	700 ug/L	2 ug/L	NS	10 ug/L	1 ug/L	1 mg/L	2500 ug/L	.07 ug/L	15 ug/L	NS	200 ug/L	1 ug/L	18 ug/L	100 ug/L	NS	20 ug/L	20000 ug/L	2100 ug/L	.2 ug/L	.3 ug/L	1 mg/L	250 mg/L	250 mg/L	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
Aluminum (ug/L)	Antimony (ug/L)	Arsenic (ug/L)	Barium (ug/L)	Beryllium (ug/L)	Boron (ug/L)	Cadmium (ug/L)	Calcium (ug/L)	Chromium (ug/L)	Cobalt (ug/L)	Copper (mg/L)	Iron (ug/L)	Hexavalent Chromium (ug/L)	Lead (ug/L)	Magnesium (ug/L)	Manganese (ug/L)	Mercury (ug/L)	Molybdenum (ug/L)	Nickel (ug/L)	Potassium (ug/L)	Selenium (ug/L)	Sodium (ug/L)	Strontium (ug/L)	Thallium (ug/L)	Vanadium (ug/L)	Zinc (mg/L)	Chloride (mg/L)	Sulfate (mg/L)	Alkalinity (mg/L)	Bicarbonate (mg/L)	Carbonate (mg/L)	Total Dissolved Solids (mg/L)	Total Suspended Solids (mg/L)	Turbidity (NTU)	pH (su)	Temperature (°C)	Specific Conductance (umhos/cm)	Dissolved Oxygen (mg/L)	Oxidation-Reduction Potential (mV)															
Marshall Steam Station	8566 Island Point Road Sherrills Ford, NC 28673	Private	MR26	1		< 50	< 1	< 5	56	< 1	< 100	< 0.1	7700	1	< 1	0.009	< 50	< 10	< 2	2700	< 5	< 0.2	< 5	< 5	2000	< 5	6800	170	< 0.1	3	0.007	2.68	1.12	36.3	36.3	< 0	80	< 1	< 1	6.2	17.2	92.6	5.9	236									
Marshall Steam Station	8455 E NC 150 Highway Terrell, NC 28662	Public	MR28	1		< 10	< 0.5	< 0.5	44.5	< 0.2	< 5	< 0.08	12600	1	< 0.5	0.0363	114	0.064	1.2	2500	4.4	< 0.2	< 0.5	1.1	2260	< 0.5	8060	162	< 0.1	1.9	0.151	14.3 M1	2.4	35.5	35.5	< 5	105	< 2.5	< 1	6.2	16.6	130.4	6.6	184.8									
Marshall Steam Station	8320 E NC 150 Highway Terrell, NC 28662	Public	MR30	1		25.9 J	< 0.40 J	0.39 J	30.5	< 0.11 J	< 20 J	< 0.06 J	13000	3.22	< 0.03 J	0.0058 J	77	2.74	0.41 J	2290	< 2	< 0.01 J	0.67 J	0.61	1740	0.43 J	9260	163	< 0.06 J	2.24	0.0501	1	5	49**	NA	NA	68	< 2.5	< 1	6.36	15.6	191	5.41	NA									
Marshall Steam Station	8457 Sherrills Ford Road Sherrills Ford, NC 28673	Private	MR32	1	high turbidity	0.0018 51.2	< 1	< 5	130	< 1	< 100	< 0.1	15000	2	2	0.043	3100	< 10	8	1800	130	< 0.2	< 5	< 5	3500	< 5	5400	110	0.1	8	0.118	5.72	< 1	32.3	32.3	< 0	106	105	28	6	18.8	117	6.6	215									
Marshall Steam Station	8499 Island Point Road Sherrills Ford, NC 28673	Private	MR4	1		33 J	< 1	0.66 J	370	0.19 J	< 25	0.12 B	41000	< 5	0.36 J	0.00088 J	1200	< 20	0.13 J	12000 B	30.8	0.041 B1	< 10	3.5 J	5000 B	0.3 J	19000	580	< 0.5	< 5	0.0099 B1	55	< 1	86	86	< 10	200 B	4.7	2.5	7.09	14.1	387	4.82	5.4									
Marshall Steam Station	8833 Greenwood Road Terrell, North Carolina 28682	Private	MR44	1		< 10	< 0.5	< 0.5	33	< 0.2	5.1	< 0.08	9060	1.2	< 0.5	0.0085	377	0.54	0.33	2190	0.96	< 0.2	< 0.5	< 0.5	1780	< 0.5	8340	196	< 0.1	5.1	0.0159	1.6	< 2	39.4	39.4	< 5	99	< 2.6	3.2	6.2	16.9	103.4	6.6	182.5									
Marshall Steam Station	8665 Island Point Road Sherrills Ford, NC 28673	Private	MR6	1		< 50	< 0.5	0.1 J	52.9	< 0.5	< 50	< 0.15	9980	1.74 J	< 1	0.0568	201	< 5	0.65	2420	< 2	< 0.2	< 2	0.39 J	2130	< 2	9280	309	< 0.5	1.29	0.0336	4	< 5	38**	NA	NA	119	< 2.5	< 1	5.98	12.3	135	8.39	NA									
Marshall Steam Station	8316 Sherrills Ford Road Sherrills Ford, NC 28673	Private	MR8	1		10.3 J	< 0.4 J	0.16 J	12.7	< 0.11 J	< 20 J	< 0.03 J	0.0134	19.8 J	< 5	0.78	1670	1.43 J	< 0.01 J	2.8	0.3 J	1570	0.32 J	7250	50	< 0.06 J	2.65	0.0211	2	< 5	36**	NA	NA	95	< 2.5	< 1	6.33	12.7	106	7.98	NA												
Marshall Steam Station	2971 Steam Plant Road Sherrills Ford, NC 28673	Private	MR9	1		< 40	< 1	0.39 J	18.8	< 0.4	< 25	< 0.1	7300	< 5	0.05 J	0.051 B	180	< 20	22	1300	0.71 B1	0.027 B1	< 10	2.4 J	770	< 1	6500 B	81	< 0.5	5.8	0.15	1.3	< 1	29	29	< 10	88.8	< 1	6.73	14.4	76	8.76	110										
Mayo Steam Station	12015 Boston Road Roxboro, NC 27574	Private	MY3	1	high turbidity	3480	< 3	< 10	70.2	< 1	< 100	< 1	22500	< 10	< 5	0.051	1790	< 20	20.9	3130	< 10	30700	436	< 1	3.03 J	0.0124	37.5	60	28.5	28.5	< 1	293	13.4	29.7	5.71	15.5	399	3.28	NA														
Roxboro Steam Station	921 Shore Road Senora, NC 27343	Private	RO1	1		< 50	< 3	< 10	3.62 J	< 1	< 100	< 1	75400	< 10	< 5	< 0.01	< 50	< 20	1.73 J	33900	8.29 J	< 0.2	< 10	< 10	1620	2.39 J	22900	390	< 1	2.84 J	0.0147	39.4	51	274	274	< 1	405	< 5	< 1	6.91	16.3	505	4.01	NA									
Roxboro Steam Station	7391 Senora Road Senora, NC 27343	Public	RO10	2	Well 1 - Pre treatment	< 100 D3	< 5 D3	< 5 D3	300	< 2 D3	< 50 D3	< 0.8 D3	145000	< 5 D3	< 5 D3	< 0.01 D3	< 500 D3	0.062	< 1 D3	61200	1010	< 0.2	< 5 D3	< 5 D3	6460	< 5 D3	59800	936	< 1 D3	< 10 D3	< 0.05 D3	335	17.3	259	259	< 5	999	< 2.5	1.5	6.48	21.8	184.2	3.8	205.3									
Roxboro Steam Station	7391 Senora Road Senora, NC 27343	Public	RO10	2	Well 2 - Pre treatment	155	< 5 D3	< 5 D3	119	< 2 D3	< 50 D3	< 0.8 D3	66600	< 5 D3	< 5 D3	< 0.01 D3	1380	< 0.03	1.7	21900	338	< 0.2	< 5 D3	< 5 D3	4270	< 5 D3	25500	263	< 1 D3	< 10 D3	< 0.05 D3	30.3	27	214	214	< 5	369	7.8	6.2	6.65	19.2	631	0.61	219.2									
Roxboro Steam Station	399 Dunaway Road Senora, NC 27343	Private	RO2	1		< 100 D3	< 5 D3	< 5 D3	64.4	< 2 D3	< 50 D3	< 0.8 D3	50700	< 5 D3	< 5 D3	0.0391	< 500 D3	0.11 M1	1.8	25100	< 5 D3	< 0.2	< 5 D3	< 5 D3	3500	< 5 D3	34000	191	< 1 D3	< 10 D3	0.0874	24	71	204	204	< 5	383	5.1	< 1	6.63	17.2	640	5.1	259.3									
Roxboro Steam Station	381 Dunaway Road Senora, NC 27343	Private	RO3	1		< 50	< 1	< 1	65	< 1	86 J	0.072 J	63000	< 1	< 1	0.0061	< 50	< 10	0.19 J	25000	< 5	< 0.2	2.5	0.54 J	5100	< 1	34000	180	< 1	2 J	0.016	47	71	190	190	< 5	410	< 3.3	0.15 J	6.3	15.4	542	5.4	160									
Roxboro Steam Station	156 The Johnson Lane Senora, NC 27343	Private	RO4	1		< 10 J	< 0.4 J	0.2 J	66.1	< 0.11 J	< 20 J	< 0.06 J	47800	2.89	0.25 J	0.00227	228	2.69	0.43 J	18800	144	< 0.01 J	0.38 J	1.35	2750	0.51 J	16400	260	< 0.06 J	1.38	0.0196	17	7	164**	NA	NA	267	< 2.5	< 1	6.77	12.9	400	4.72	NA									
Roxboro Steam Station	285 Dunaway Road Senora, NC 27343	Private	RO6	1		< 10	< 0.5	< 0.5	51	< 0.2	< 5	< 0.08	59700 M1	< 0.5	< 0.5	0.0254	< 50	0.19	40.3	24400 M1	1.9	< 0.2	0.74	< 0.5	4310 M1	255	< 0.1	4.5	0.0405	44.2	29.2	2	178 M1	178	< 5	366	< 2.5	< 1	6.69	13.2	596.2	2.3	257.7										
Sutton Power Station	4600 421 Highway N Wilmington, NC	Public	S1	2		253	< 1	< 5	37	< 1	15	< 2	3720	< 5	< 1	0.003	58	< 0.1	< 3	602	25	< 0.2	< 5	< 5	716	< 5	2900	16	< 0.2	0.3	0.015	4.87	9.67	2.59	2.59	< 1	32	< 2.5	< 1	5.58	18.8	53	6.24	NA									
Sutton Power Station	4600 421 Highway N Wilmington, NC	Public	S1	2	Invista OH-2-DW3	142	< 1	< 5	48	< 1	24	< 2	4280	< 5	< 1	+ 0.003	70	< 0.1	4	1038	23	< 0.2	< 5	< 5	993	< 5	4510	25	< 0.2	< 0.3	0.011	8.02	10.1	1.99	1.99	< 1	37.5	< 2.5	< 1	6.75	16.6	62.5	9.22	NA									
Sutton Power Station	3857 421 Highway N Wilmington, NC	Public	S12	1		109	< 1	< 5	33	< 1	34	< 2	27400	< 5	< 1	< 0.003	258	< 0.1	< 3	1800	66	< 0.2	< 5	< 5	1200	< 5	3080	70	< 0.2	< 0.3	< 0.005	5.29	28.9	42.8	42.8	< 1	104	< 2.5	< 1	6.85	16.6	178	8.45	NA									
Sutton Power Station	230 Sutton Lake Road Wilmington, NC	Public	S2	2	Pump House Well	110	< 1	0.567 J	46	< 1	690	< 1	19900	< 1	2	0.003	24	< 0.02	< 1	3140	295	< 0.4	0.641 J	< 100	3380	< 10	18300	365	< 1	0.256 J	0.00914 J	25	69	4	4	< 1	159	< 2.5	0.5	5.44	21.9	263	5.8	NA									
Sutton Power Station	230 Sutton Lake Road Wilmington, NC	Private	S2	2	Combined Production Wells	45	< 1	0.576 J	47	< 1	160	< 1	60700	0.176 J	2	0.004	635	< 0.02	< 1	5460	278	< 0.4	0.758 J	< 100	9980	1	24100	287	< 1	0.386 J	0.015	25	160	36	36	< 1	126	< 2.5	5.3	6.02	18.7	506	6.6	NA									
Sutton Power Station	235 Sutton Lake Road Wilmington, NC	Private	S3	1		42	< 1	0.446 J	400	< 1	600	< 1	21400	0.244 J	2	0.001	389	< 0.02	0.661 J	3450	224	< 0.4	< 1	2.21 J	4110	< 10	20200	382	< 1	0.197 J	0.00769 J	20																					