

		15A NCAC 02.0202 Groundwater Standard:																																										
		Federal MCL (if denotes secondary standard)																																										
		DHS Screening Level																																										
Coal Ash Facility	Property Address	Public or Private	Well Owner ID	No. of Wells on Property	Notes	Aluminum (ug/L)	Antimony (ug/L)	Arsenic (ug/L)	Barium (ug/L)	Beryllium (ug/L)	Boron (ug/L)	Cadmium (ug/L)	Calcium (ug/L)	Chromium (ug/L)	Cobalt (ug/L)	Copper (mg/L)	Iron (ug/L)	Hexavalent Chromium (ug/L)	Lead (ug/L)	Magnesium (ug/L)	Manganese (ug/L)	Mercury (ug/L)	Molybdenum (ug/L)	Nickel (ug/L)	Potassium (ug/L)	Selenium (ug/L)	Sodium (ug/L)	Strontium (ug/L)	Thallium (ug/L)	Vanadium (ug/L)	Zinc (ug/L)	Chloride (mg/L)	Sulfate (mg/L)	Alkalinity (mg/L)	Bicarbonate (mg/L)	Carbonate (mg/L)	Total Dissolved Solids (mg/L)	Total Suspended Solids (mg/L)	Turbidity (NTU)	pH (au)	Temperature (°C)	Specific Conductance (µm/cm)	Dissolved Oxygen (mg/L)	Oxidation-Reduction Potential (mv)
Allen Steam Station	2072 South Point Road Belmont, NC 28012	Private	AL1	1	Filter prior to sample port.	<50	<1	<5	26	<1	<100	<0.1	15000	<1	<1	0.01	65	<10	<2	2800	<5	<0.2	<5	<5	2100	<5	6700	130	<0.1	5	0.155	4.63	<1	47	47	<0	98	<1	<1	6.6	18.1	128	6.9	207
Allen Steam Station	2360 South Point Road Belmont, NC 28012	Private	AL2	1		21.9	<0.5	0.64	22.2	<0.2	6.6	<0.08	16500	1.5	<0.5	<0.001	<50	1	0.12	4320	0.92	<0.2	1.2	<0.5	2170	0.66	8210	142	<0.1	9.9	0.0077	2.6	3	60.7	60.7	<5	114	<2.5	<1	7	17.2	158.6	5.3	168.8
Allen Steam Station	2320 South Point Road Belmont, NC 28012	Private	AL3	1		68	0.2 J	<1	17	<1	49 J	<1	4600	1.1	0.099 J	1.1 J	1000	<10	0.46 J	1700	5.2	<0.2	0.36 J	0.33 J	1300	<1	5700	74	<1	6.8	0.033	2	0.15 J	26	26	<5	70	<3.1	0.9 J	6.3	16.2	55	10.3	221
Allen Steam Station	2330 South Point Road Belmont, NC 28012	Private	AL5	1		45 J	<1	<5	20	<1	<100	<0.1	7500	3	<1	0.104	75	4 J	11	2700	<5	<0.2	2 J	<5	1500	<5	5900	110	<1	14	0.041	2.44	1.11	36.3	36.3	<0	88	1.4	<1	6.8	17.5	91	4.8	183
Allen Steam Station	101 Mitchell Street Belmont, NC 28012	Private	AL6	1		<50	<3	<10	30.5	<1	<100	<1	7180	<10	<5	<0.01	<50	<20	<5	2310	<10	<0.2	<10	1360	<10	6410	90.2	<1	4.49 J	<0.01	2.85	<10	31.7	31.7	<1	81	<5	<1	6.99	14.5	111	6.95	NA	
Allen Steam Station	101 Mitchell Street Belmont, NC 28012	Private	AL6R	1		<10	<0.5	<0.5	30	<0.2	<5	<0.08	6790	3.5	<0.5	0.0011	60.8	3.2	<0.1	2200	<0.5	<0.2	<0.5	<0.5	1410	<0.5	6100	94	<0.1	6.4	<0.005	3	2.1 M1	26.8 M1	25.8	<5	86	<2.5	<1	6.5	18.6	74.6	6.8	302.68
Allen Steam Station	97 Mitchell Street Belmont, NC 28012	Private	AL7	1		<10	<0.5	<0.5	18.8	<0.2	<5	<0.08	14400	1.2	<0.5	0.0011	<50	0.97	0.11	5460	<0.5	<0.2	<0.5	<0.5	1790	<0.5	8340	180	<0.1	10.9	0.0176	3.7	<2	58.7	58.7	<5	119	<2.5	<1	6.9	16.9	141.8	8.1	155
Allen Steam Station	2343 South Point Road Belmont, NC 28012	Private	AL8	1		<50	0.08 J	<1	53	<1	97 J	<1	13000	3	<1	0.04	<50	<10	1.7	4700	<5	<0.2	0.4 J	0.55 J	1600	<1	9100	240	<1	8.1	0.016	4.6	<1	51	NA	<5	130	<3.1	0.27 J	6.1	17.8	133	7.3	NA
Allen Steam Station	2347 South Point Road Belmont, NC 28012	Private	AL9	1		<50	<1	<5	54	<1	<100	<0.1	21000	6	<1	0.006	<50	5 J	<2	6600	<5	<0.2	<5	<5	1400	<5	11000	300	<0.1	7	0.172	8.06	1.22	65.7	65.7	<0	165	<1	<1	6.2	18.7	205	6	259
Allen Steam Station	2369 South Point Road Belmont, NC 28012	Private	AL11	1		<50	<3	<10	33.4	<1	<100	<1	10500	2.28 J	<5	0.00416 J	<50	<20	2.98 J	2910	<10	<0.2	<10	<10	1550	<10	8360	135	<1	4.35 J	0.00499 J	4.28	<10	45.4	45.4	<1	104	<5	<1	6.68	19.3	157	6.52	NA
Allen Steam Station	2369 South Point Road Belmont, NC 28012	Private	AL11R	1		<10	<0.5	<0.5	31.1	<0.2	<5	<0.08	10200	2.6	<0.5	0.0035	<50	1.6	0.84	2660	<0.5	<0.2	<0.5	0.64	1530	<0.1	8070	153	<0.1	5.2	0.0064	3.7	2.2	37.2	37.2	<5	118	<2.5	<1	6.5	17.6	36.3	7.9	202.6
Allen Steam Station	2401 South Point Road Belmont, NC 28012	Private	AL12	1		<10	<0.5	<0.5	58.2	<0.2	<5	<0.08	21200	1.7	<0.5	0.0314	<50	1.5	0.65	3620	0.8	<0.2	<0.5	<0.5	1930	<0.5	8690	286	<0.1	2.4	0.0255	8.4	4.5	45.4	49.5	<1	146	<2.5	<1	6.1	19.1	177.4	6.1	258.6
Allen Steam Station	2411 South Point Road Belmont, NC 28012	Private	AL14	1	Unable to collect samples from the well head due to pressure tank at well. Samples were collected from the spigot on the back of the house.	<50	<1	<5	96	<1	<100	<0.1	31000	4	<1	0.03	<50	5 J	<2	7900	<5	<0.2	<5	<5	1900	<5	10000	360	<0.1	2	0.021	22.3	6.92	61.7	61.7	<0	214	<1	<1	5.9	19.2	276	5.8	213
Allen Steam Station	2417 South Point Road Belmont, NC 28012	Private	AL15	1	Per lab, no tap @ well head and no treatment devices.	<50	<3	<10	49.2	<1	<100	<1	19600	<10	<5	0.0276	14.5 J	<20	<5	6080	<10	<0.2	<10	<10	1570	<10	9300	222	<1	3.68 J	<0.01	7.6	<10	72.8	72.8	<1	138	<5	<1	6.69	15.7	252	5.82	NA
Allen Steam Station	114 Warren Drive Belmont, NC 28012	Private	AL16	1	Unable to collect samples from the well head. Samples were collected from the spigot on front of house.	89	<1	<5	16	<1	<100	<0.1	11000	2	<1	0.006	510	<10	<2	2600	9	<0.2	<5	<5	1000	<5	8000	150	<0.1	3	0.784	3.86	<1	53.9	53.9	<0	96	1.9	11	6.3	20.1	114	5	145
Allen Steam Station	310 Mitchell Street Belmont, NC 28012	Private	AL17	1	Per lab, no well head tap. Sample taken from outside tap. No treatment.	<50	<3	<10	31.4	<1	<100	<1	13500	<10	<5	0.0162	57.7	<20	<5	3860	137 J	<0.2	<10	<10	1180	<10	9650	160	<1	5.58	0.0173	3.8	<10	56.9	56.9	<1	106	<5	<1	6.45	15.5	176	5.87	NA
Allen Steam Station	310 Mitchell Street Belmont, NC 28012	Private	AL17R	1		14.3	<0.5	<0.5	30	<0.2	<5	<0.08	13100	1.4	<0.5	0.0171	59.3	1.1	0.8	3700	1.7	<0.2	<0.5	<0.5	1200	<0.5	9360	168	<0.1	7.8	0.0152	4.3	2.1	46.4	46.4	<5	130	<2.5	<1	6.5	17.3	131	6.4	359.7
Allen Steam Station	318 Mitchell Street Belmont, NC 28012	Private	AL19	1	Per lab, no tap @ well head. Outside spigot closest to well. No treatment.	<50	<3	<10	51	<1	<100	<1	16600	<10	<5	0.033	19.4 J	<20	<5	5180	<10	<0.2	<10	<10	2000	<10	9830	228	<1	3.84 J	0.0112	8.08	<10	55.9	55.9	<1	155	<5	<1	6.76	15.3	242	5.48	NA
Allen Steam Station	131 South Point Drive Belmont, NC 28012	Private	AL20	1		<50	<3	<10	21.7	<1	<100	<1	13400	<10	<5	<0.01	<50	<20	<5	4390	<10	<0.2	<10	<10	1430	<10	7950	165	<1	10.3	<0.01	4.28	<10	65.7	65.7	<1	84	<5	<1	7.11	13.8	174	6.12	NA
Allen Steam Station	135 South Point Drive Belmont, NC 28012	Private	AL21	1		<50	<3	<10	23.2	<1	<100	<1	13800	<10	<5	<0.01	<50	<20	<5	5190	<10	<0.2	<10	<10	1740	<10	7910	152	<1	11.7	0.0575 J	2.38	<10	70.1	70.1	<1	84	<5	<1	7.24	13.6	191	6.91	NA
Allen Steam Station	135 South Point Drive Belmont, NC 28012	Private	AL21R	1		<10	<0.5	<0.5	22.5	<0.2	<5	<0.08	13200	0.92	<0.5	<0.001	<50	0.74	<0.1	4920	<0.5	<0.2	<0.5	<0.5	1850	<0.5	7890	158	<0.1	12.6	<0.005	2.5	2.2	63.3	63.3	<5	119	<2.8	<1	6.9	14.2	5.4	291.4	
Allen Steam Station	127 South Point Drive Belmont, NC 28012	Private	AL22	1		12.4	<0.5	<0.5	1.2	<0.2	<5	<0.08	21700	0.58	<0.5	<0.001	<50	0.15	0.39 M1	4750	0.5	<0.2	<0.5	<0.5	2140	<0.5	6690	109	<0.1	8.9	<0.005	3.8	3.2 M1	74.1	74.1	<5	133	<5	<1	7.4	8	167.5	3.9	132.6
Allen Steam Station	122 South Point Drive Belmont, NC 28012	Private	AL23	1		19 J	<1	<1	15	<0.40	<25	<0.1	10000	<5.0	0.79 J	0.018 B	310	<20	0.13 J	3800	1.4 J	0.05 B	0.57 J	1.5 J	2000	<1.0	6400	100	<0.50	13	0.054 J	2.2	0.64 J	44	44	<10	57	0.50 J	<10	6.99	14.1	79	5.52	94
Allen Steam Station	122 South Point Drive Belmont, NC 28012	Private	AL23R	1		22.5	<0.5	<0.5	14.8	<0.2	<5	<0.08	10800	1.5	<0.5	0.0016	<50	1.1	<0.1	3820	1.1	<0.2	0.54	0.51	2070	<0.5	6670	110	<0.1	13.4	0.0061	2	2.2	39.7	39.7	<5	94	2.6	<1	7	17.2	114.1	5.3	272.8
Allen Steam Station	116 South Point Drive Belmont, NC 28012	Private	AL24	1		<50	<1	<5	10	<1	<100	<0.1	11000	<1	<1	<0.005	<50	<10	<2	3200	<5	<0.2	2 J	<5	1800	<5	5700	82	<0.1	1.2	0.011	2.11	1.86	49	49	<0	99	<1	<1	7.3	20.1	116	4.9	197
Allen Steam Station	110 South Point Drive Belmont, NC 28012	Private	AL25	1	Per lab, outside spigot and no treatment devices.	<50	0.081 J	<1	73	<1	<500	<1	15000	1.4	<1	0.059	<50	<10	0.3 J	3900	0.63 J	<0.2	0.14 J	0.24 J	2400	<1	9800	230	<1	4.3 J	0.028 B	4.2	<1	60	60	<5	140	<3.3	0.15 J	6.2	15.7	162	8.6	215
Allen Steam Station	305																																											

				15A NCAC 02L .0202 Groundwater Standard:																																												
				NS	1 ug/L	10 ug/L	700 ug/L	4 ug/L	700 ug/L	2 ug/L	NS	10 ug/L	1 ug/L	1 mg/L	300 ug/L	NS	15 ug/L	NS	50 ug/L	1 ug/L	NS	100 ug/L	NS	20 ug/L	NS	NS	0.2 ug/L	0.3 ug/L	1 mg/L	250 mg/L	250 mg/L	NS	NS	NS	500 mg/L	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS			
				Federal MCL (* denotes secondary standard)																																												
				*50 to 200 ug/L	6 ug/L	10 ug/L	2000 ug/L	4 ug/L	NS	5 ug/L	NS	100 ug/L	NS	1.3 mg/L	*300 ug/L	NS	15 ug/L	NS	*50 ug/L	2 ug/L	NS	NS	NS	50 ug/L	NS	NS	2 ug/L	NS	*5 mg/L	*250 mg/L	*250 mg/L	NS	NS	NS	*500 mg/L	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	
				DHHS Screening Level																																												
				3500 ug/L	1 ug/L	10 ug/L	700 ug/L	4 ug/L	700 ug/L	2 ug/L	NS	10 ug/L	1 ug/L	1 mg/L	2500 ug/L	07 ug/L	15 ug/L	NS	200 ug/L	1 ug/L	18 ug/L	100 ug/L	NS	20 ug/L	20000 ug/L	2100 ug/L	2 ug/L	3 ug/L	1 mg/L	250 mg/L	250 mg/L	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
Coal Ash Facility	Property Address	Public or Private	Well Owner ID	No. of Wells on Property	Notes	Aluminum (ug/L)	Antimony (ug/L)	Arsenic (ug/L)	Barium (ug/L)	Beryllium (ug/L)	Boron (ug/L)	Cadmium (ug/L)	Calcium (ug/L)	Chromium (ug/L)	Cobalt (ug/L)	Copper (mg/L)	Iron (ug/L)	Hexavalent Chromium (ug/L)	Lead (ug/L)	Magnesium (ug/L)	Manganese (ug/L)	Mercury (ug/L)	Molybdenum (ug/L)	Nickel (ug/L)	Potassium (ug/L)	Selenium (ug/L)	Sodium (ug/L)	Strontium (ug/L)	Thallium (ug/L)	Vanadium (ug/L)	Zinc (mg/L)	Chloride (mg/L)	Sulfate (mg/L)	Alkalinity (mg/L)	Bicarbonate (mg/L)	Carbonate (mg/L)	Total Dissolved Solids (mg/L)	Total Suspended Solids (mg/L)	Turbidity (NTU)	pH (au)	Temperature (°C)	Specific Conductance (umhos/cm)	Dissolved Oxygen (mg/L)	Oxidation-Reduction Potential (mv)				
Allen Steam Station	130 Midwood Lane Belmont, NC 28012	Private	AL69	1	< 10 M1, R1	< 10	< 0.5	< 0.5	40	< 0.2	< 5	< 0.08	16000	1.8	< 0.5	0.0748	75.8	1.2	0.32	5280 M1	1.9	< 0.2	< 0.5	1720	< 0.5	8420	219 M1	< 0.1	8.4	0.0446	3.8	< 2	55.3	55.3	< 5	141	< 2.5	< 1	6.5	17.3	153.5	4.9	202.3					
Allen Steam Station	128 Midwood Lane Belmont, NC 28012	Private	AL70	1	< 50	< 3	< 10	42.9	< 1	< 100	< 1	22300	1.80 J	< 5	0.00652 J	33.4 J	< 20	2.45 J	8960	< 10	< 0.2	< 10	< 10	2160	< 10	9650	240	< 1	8.09	< 0.01	8.08	< 10	87.6	87.6	< 1	158	< 2.5	< 1	6.73	17.7	295	5.17	NA					
Allen Steam Station	128 Midwood Lane Belmont, NC 28012	Private	AL70R	1	< 10	< 0.5	< 0.5	48.3	< 0.2	< 5	< 0.08	22000	1.8	< 0.5	0.0075	50	1.6	0.28	8050	< 0.5	< 0.2	< 0.5	0.57	2280	< 0.5	9700	265	< 0.1	9.4	< 0.005	8.9	2.7	75.3	75.3	< 5	162	< 2.5	< 1	6.5	18.6	180	3.7	262.3					
Allen Steam Station	126 Midwood Lane Belmont, NC 28012	Private	AL71	1	< 10	< 0.5	< 0.5	35.8	< 0.2	< 5	< 0.08	23800	1.5	< 0.5	0.0739	< 50	1	0.29	8430	< 0.5	< 0.2	< 0.5	0.5	2120	< 0.5	9570	256	< 0.1	9.2	0.013	9.5	< 2	73.6	73.6	< 5	149	< 2.5	< 1	6.5	18	212.6	3.3	271					
Allen Steam Station	124 Midwood Lane Belmont, NC 28012	Private	AL72	1	< 10	< 0.5	< 0.5	30	< 0.2	< 5	< 0.08	23300	2.5	< 0.5	0.0032	< 50	1.1	1.4	7650	7.7	< 0.2	< 0.5	< 0.5	1820	< 0.5	9640	265	< 0.1	5.1	0.0623	9	< 2	69.9	69.9	< 5	132	< 2.5	< 1	6.5	18.4	200.3	2.8	169.8					
Allen Steam Station	122 Midwood Lane Belmont, NC 28012	Private	AL73	1	< 10 J	< 0.4 J	0.12 J	35.3	< 0.11 J	< 20 J	< 0.06 J	14500	3.11	< 0.03 J	0.026	55	< 5	0.65	4810	< 0.84 J	< 0.01 J	< 0.12 J	0.75	1510	< 0.16 J	8890	188	< 0.06 J	9.6	0.00709	4	< 5	69 **	NA	NA	61	< 2.5	< 1	6.63	14.4	167	6.99	NA					
Allen Steam Station	120 Midwood Lane Belmont, NC 28012	Private	AL74	1	< 10	< 0.5	< 0.5	51.1	< 0.2	< 5	< 0.08	21000	2.1	< 0.5	0.126	< 50	2	0.34	6540	2.2	< 0.2	< 0.5	< 0.5	2080	< 0.5	10100	293	< 0.1	5.8	0.0124	10.9	< 2	69.8 M1	69.8	< 5	168	< 2.5	< 1	6.3	18.3	176.3	4	178.4					
Allen Steam Station	119 Idlewood Lane Belmont, NC 28012	Private	AL75	1	< 50	0.095 J	< 1	12	< 1	< 500	< 1	6600	1.2	< 1	0.048	< 50	< 10	1.4	3500	1 J	< 0.2	0.17 J	0.26 J	1500	< 1	6600	86	< 1	14	0.038 BH, B	2.1	< 1	43	43	< 5	110	< 3.3	0.31 J	6.4	14.2	91	7.4	179					
Allen Steam Station	118 Idlewood Lane Belmont, NC 28012	Private	AL76	1	< 10 J	< 0.4 J	0.13 J	11.9	< 0.11 J	< 20 J	< 0.06 J	7120	2.62	< 0.03 J	0.00732	< 25	2.62	0.13 J	2760	1.5 J	< 0.01 J	< 0.12 J	0.45 J	1120	< 0.16 J	6820	109	< 0.06 J	8.34	0.0266	2	< 5	35 **	NA	NA	87	< 2.5	< 1	6.41	16.1	110	7.87	NA					
Allen Steam Station	117 Idlewood Lane Belmont, NC 28012	Private	AL77	1	< 10	< 0.5	< 0.5	49	< 0.2	< 5	< 0.08	15300	1	< 0.5	0.104	< 50	0.7	0.24	4980	0.84	< 0.2	< 0.5	< 0.5	2160	< 0.5	9940	238	< 0.1	8.5	0.0543	7.7	2.5	44.1	44.1	< 5	157	< 2.5	< 1	6.4	18.5	175.4	5.6	264.2					
Allen Steam Station	116 Idlewood Lane Belmont, NC 28012	Private	AL78	1	< 10	< 0.5	< 0.5	26	< 0.2	< 5	< 0.08	6290	< 0.5	< 0.5	0.247	< 50	0.1	0.19	1590	1	< 0.2	< 0.5	< 0.5	1060	< 0.5	5320	86.1	< 0.1	2.1	0.126	2.9	< 2	19	19	< 5	70	< 2.5	< 1	6.1	17.7	75.8	7.2	231.2					
Allen Steam Station	115 Idlewood Lane Belmont, NC 28012	Private	AL79	1	< 10	< 0.5	< 0.5	24.8	< 0.2	< 5	< 0.08	11700	0.6	< 0.5	0.0395	54.9	0.33	0.29	3230	0.71	< 0.2	< 0.5	< 0.5	2240	< 0.5	8320	157	< 0.1	4.4	0.0203	6.5	2.1	40.9	40.9	< 5	104	< 2.5	< 1	6.3	17.8	128.3	5.8	183.4					
Allen Steam Station	2509 South Point Road Belmont, NC 28012	Private	AL82	1	< 10	< 0.5	< 0.5	69.5	< 0.2	< 5	< 0.08	24300	1.4	< 0.5	0.182	< 50	0.81	0.23	7600	1.7	< 0.2	< 0.5	0.71	2400	< 0.5	12300	392	< 0.1	4.7	0.0199	14.3	2.1	47.8	47.8	< 5	223	< 2.5	< 1	6.3	22.3	254	5.4	273.3					
Allen Steam Station	2505 South Point Road Belmont, NC 28012	Private	AL83	1	< 10	< 0.5	< 0.5	42.1	< 0.2	< 5	< 0.08	21300	3.5	< 0.5	0.104	< 50	3.5	0.24	8060	1.5	< 0.2	< 0.5	1.3	1760	< 0.5	10800	289	< 0.1	9	0.0299	15.3	3.9	49.5	49.5	< 5	228	< 2.5	< 1	6.2	19.4	223.7	5.6	200.4					
Allen Steam Station	2501 South Point Road Belmont, NC 28012	Private	AL84	1	< 10	< 0.5	< 0.5	23.5	< 0.2	< 5	< 0.08	13600	0.55	< 0.5	0.016	59.8	0.59	0.22	6030	15.7	< 0.2	< 0.5	< 0.5	1880	< 0.5	9050	185	< 0.1	8.2	0.0794	6.6	< 2	46.7	46.7	< 5	134	< 2.5	< 1	6.8	17	179.1	5.2	180.6					
Allen Steam Station	185 Reese Wilson Road Belmont, NC 28012	Private	AL85	1	< 10	< 0.5	< 0.5	13	< 0.2	< 5	< 0.08	4720	2.6	< 0.5	0.0046	< 50	2.5	< 0.1	1420	< 0.5	< 0.2	< 0.5	< 0.5	978	< 0.5	4900	69.2	< 0.1	9.6	0.0098	1.4	< 2	19.6	19.6	< 5	67	< 2.5	< 1	6.7	18.3	61.5	8.7	219.8					
Allen Steam Station	105 Reese Wilson Road Extension Belmont, NC 28012	Private	AL89	1	< 50	0.14 J	0.31 J	26	< 1	67 J	< 1	7600	2.9	< 1	0.021	< 100	< 10	1.1	2500	0.72 J	< 0.2	0.39 J	0.44 J	1500	< 1	6400	120	0.1 J	11	0.037 BH, B	1.9	< 1	43	43	< 5	140	< 3.3	0.29 J	6.5	14.9	83	9.6	173					
Allen Steam Station	112 Reese Wilson Road Belmont, NC 28012	Private	AL90	1	< 50	< 1	< 5	54	< 1	< 100	< 0.1	11000	3	< 1	0.046	2100	< 10	7	2700	6	< 0.2	< 5	< 5	1700	< 5	7300	160	< 0.1	10	0.031	15.4	< 1	39.2	39.2	< 0	96	5.1	13	6	19.3	107	7.6	205					
Allen Steam Station	210 Reese Wilson Road Belmont, NC 28012	Private	AL91	1	< 10	< 0.5	< 0.5	8.1	< 0.2	< 5	< 0.08	11300	2.1	< 0.5	0.0015	67.6	1.5	0.16	3720	0.5	< 0.2	< 0.5	< 0.5	1940	< 0.5	6140	127	< 0.1	12.2	0.1	1.5	2	46.1 M1	46.1	< 5	98	< 2.6	< 1	7.1	16.4	109	7	245					
Allen Steam Station	2718 South Point Road Belmont, NC 28012	Private	AL92	1	< 50	< 1	< 5	20	< 1	< 100	< 0.1	9300	< 1	< 1	0.008	< 50	< 10	< 2	2100	< 5	< 0.2	< 5	< 5	1600	< 5	6900	110	< 0.1	5	0.007	3.8	< 1	33.3	33.3	< 0	65	< 1	< 1	6.3	19.8	97.2	6.6	232					
Allen Steam Station	2622 South Point Road Belmont, NC 28012	Private	AL93	1	86	0.064 J	< 1	20	< 1	90 J	< 1	8000	1.3	0.099 J	0.021	94	< 10	2.3	2500	7.7	< 0.2	0.77 J	0.68 J	2300	< 1	6700	82	< 0.1	9.6	0.074 BH, B	2.9	< 1	39	39	< 5	80	5.2	0.38 J	6.2	13.1	90	8.3	139					
Allen Steam Station	2624 South Point Road Belmont, NC 28012	Private	AL94	1	< 10 J	< 0.4 J	2.39	9.57	< 0.11 J	< 20 J	< 0.06 J	22300	1.3 J	< 0.03 J	0.013	16.3 J	< 5	0.18 J	4580	< 0.84 J	< 0.01 J	4.84	0.56 J	1600	2.49	8060	142	< 0.06 J	26.5	0.0164	2	5	79 **	NA	NA	156	< 2.5	< 1	7.59	10.9	202	6.31	NA					
Allen Steam Station	2323 South Point Road Belmont, NC 28012	Private	AL95	1	high turbidity	< 10	< 0.5	< 0.5	30.2	< 0.2	7.4	< 0.08	11900	1.8	< 0.5	0.0043	1980	1.3	1.5	3670	39.7	< 0.2	< 0.5	0.71	2030	< 0.5	9110	186	< 0.1	2.5																		





