



BOILER SAFETY BUREAU  
1101 MAIL SERVICE CENTER  
RALEIGH, NC 27699-1101  
PHONE (919) 807-2760  
FAX (919) 807-2762

Information Bulletin No.:  
Amendment: 1  
Issue Date: March 5, 2009  
Original Notification Date: March 19, 2008

## POLICY NOTIFICATION VR Adjustment and Tagging

North Carolina does take the option given in the National Board Inspection Code, Part 3, Paragraph S7.10.1 that allows properly trained and authorized non VR holders to make adjustments to pressure relief devices. Authorization must be in writing from the Boiler Safety Bureau and will only be given after proof is provided that personnel conducting adjustments have been properly trained and qualified. When a pressure relief device set pressure is adjusted, the device shall be resealed with a seal identifying the responsible organization and a metal tag installed that identifies the organization and the date of the adjustment.

JACK M. GIVEN, JR.  
CHIEF INSPECTOR