



BOILER SAFETY BUREAU
1101 MAIL SERVICE CENTER
RALEIGH, NC 27699-1101
PHONE (919) 807-2760
FAX (919) 807-2762

Information Bulletin No.: IB-13.001
Issue Date: July 23, 2013

POLICY NOTIFICATION
<Make Up Water Connection>

The provisions of North Carolina Administrative Code, paragraph .0409 (e) require that each automatically fired boiler shall be provided with a system to automatically maintain a constant water level.

The provisions of paragraph .0409 (e) do not apply to hot water heating boilers that are used in closed-loop radiant floor heating systems and that are installed in accordance with the manufacturer's instructions.

JACK M. GIVEN, JR.
CHIEF INSPECTOR