



BOILER SAFETY BUREAU
1101 MAIL SERVICE CENTER
RALEIGH, NC 27699-1101
PHONE (919) 807-2760
FAX (919) 807-2761

Information Bulletin: IB-18.002
Issue Date: 02/21/2018

POLICY NOTIFICATION
<Bladder-Type Tank Exemption>

This policy is being issued to clarify jurisdictional requirements regarding the exemption of bladder-type cold water tanks.

- Article 7A, 95-69.10(b)(14) Article of Exemptions shall include bladder type cold water tanks, only when the bladders are not continuously connected to an air delivery system, designed to monitor and maintain air pressure and/or volume.

Cliff Dautrich
Chief Inspector